

Jan. 4, 2022

RICK RICHTER
2920 VALLEYWOOD DR
ANCHORAGE, AK 99517

RE: Home heating fuel tank removal
Legal: LAKE SPENARD PARK BLK 4 TR A

Dear Mr. Richter,

Per your request, a 1000 gallon steel tank was removed from the above referenced lot and recycled to the local steel scrap yard. The tank was almost empty except of about 10 gallons of home heating fuel which was collected and recycled. During the removal process no signs of leakage were found which would indicate the tank had been compromised or leaking. The existing soils showed no signs or smells of hydrocarbons in any of the surrounding soils around the steel tank. Two small soil samples were taken for future testing if required by any local or state testing agency.

If you have any questions about this inspection letter, please call.

Respectfully,



Mike Anderson, P.E.
4661 Natrona Ave.
Anch, Ak 99516
Cell 727-8864
Attachments: None

Invoice

Michael N. Anderson, P.E.

Civil/Structural Engineering and Construction

4661 Natrona Ave.

Anchorage, Alaska 99516

Phone 727-8864

Fax 345-1391

Jan. 4, 2022

RICK RICHTER
2920 VALLEYWOOD DR
ANCHORAGE, AK 99517

Re: Fuel Tank Removal
Legal: LAKE SPENARD PARK BLK 4 TR A

Description of Excavation & Engineering Services Provided:

1. Excavation to remove 1000 gallon home heating steel tank. Tank was removed cut-up and recycled. Excess fuel was removed, about 10 gallons and recycled.
2. The tank showed no sign of leaks. Soils under the tank consisted of silty sand with no sign of leakage. No smell or discoloration was observed. Soil samples taken for testing later if required by owner.

Total due this Invoice

\$ 2,500.00

A handwritten signature, possibly 'Pd', is written over a large checkmark.